

Mennonite Mutual Fire Insurance Company

Wood Truss Warranty

All wood truss systems must be installed and braced as per manufacturer installation package information or inspected and approved by a structural engineer as one of the conditions to qualify for collapse coverage for all truss systems with greater than 24" spacing. In the absence of either of the above, for spans up to 60', the applicable requirement below will be accepted as meeting that condition.

Spans from 20' up to and including 40' will require a minimum of two continuous lateral braces on diagonal members.

Spans greater than 40' up to and including 60' will require a minimum of four continuous lateral braces on diagonal members.

In addition to the above there must be anchor and diagonal web bracing as recommended in the WWTA Handling, Erection and Bracing of Wood Trusses brochure.

Continuous bottom cord bracing is required at a minimum of 20' intervals on all buildings if the ceiling is not sheathed.